

Installation, Operating, and Safety Instructions

KEMPER MULTI-THERM Thermostatic Balancing Valve

Figure 154 02




KEMPER
DRIVING PROGRESS

Content

1 Info.....3

1.1 Safety warnings & installation instructions.....3

2 Product information.....5

2.1 Scope.....5

2.2 Technical data | Dimensions..... 5

3 Installation.....7

3.1 Assembly instructions.....7

4 Operation.....7

4.1 Adjustment of temperature set-point7

4.2 Isolation.....7

4.3 Insert a temperature probe.....8

5 Control Characteristic.....9

6 Flow diagrams.....10

1.1 Safety Warnings & Installation Instructions

READ AND UNDERSTAND THESE WARNINGS AND INSTRUCTIONS FIRST.

Labeling of important warning information:

WARNING indicates a hazardous situation which, if not avoided, could result in death or serious injury.

CAUTION indicates a hazardous situation which, if not avoided, could result in minor or moderate injury.

NOTICE is used to address practices not related to physical injury.

▲WARNING

Closely review all safety warnings in this manual before installation or use of the valve. Failure to review these safety warnings may lead to injury or property damage!

▲CAUTION

A trained and qualified plumber must install this valve.

▲CAUTION

All service and repair work should be performed by a trained and qualified plumber using suitable tools and original spare parts.

NOTICE

Check and comply with all applicable federal, state, and local safety and industry codes and standards.

Pass these instructions on to the system operator and retain for later reference!

▲CAUTION

Carefully inspect the valve before installation for any signs of damage which may have occurred during transportation or storage. Do not use the valve if it seems in any way damaged!

▲CAUTION

Make sure that the installation location is frost-proof. Perform a leak test after installation and before commissioning the plumbing installation.

▲WARNING

During valve operation, parts of the valve may heat and burn exposed skin.

NOTICE

This valve is intended for use in normal working conditions only. The responsibility for correct selection of the valve to the operating conditions, distribution, and installation is borne by the system designer, contractor, and user.

▲WARNING

Discard all unused parts and packaging material after installation in accordance with federal, state, and local requirements. **Small parts may be a choking hazard!**


Warranty Disclaimer

EXCEPT FOR THE EXPRESS WARRANTIES SET FORTH HEREIN, GEBR. KEMPER GMBH + CO. KG GRANTS NO EXPRESS OR IMPLIED WARRANTIES AND SPECIFICALLY DISCLAIMS ANY OTHER WARRANTIES, WHETHER WRITTEN OR ORAL, INCLUDING ANY WARRANTY OF QUALITY, MERCHANTABILITY, OR FITNESS FOR A PARTICULAR USE OR PURPOSE.

GEBR. KEMPER GMBH + CO. KG SHALL NOT BE LIABLE FOR DAMAGES ARISING FROM ANY DISREGARD OF THESE SAFETY WARNINGS & INSTALLATION INSTRUCTIONS, OR ANY DAMAGE CAUSED BY FAULTY INSTALLATION OF THE VALVE, ANY UNAUTHORIZED PRODUCT MODIFICATIONS, OR ANY INCORRECT OPERATION OF THE VALVE.



Fig. 154 02 | 154 04



Accessory		Part. No.
1	digital thermometer	T51001550000100

2.1 Scope


The Multi-Therm thermal balancing valve is for hydraulic balancing of hot water circulation systems. It automatically regulates the

circulation flow rate according to the pre-set temperature.

2.2 Technical data | Dimensions

Technical data	
Adjustable control range	154 02: 50 °C - 65 °C (122 °F - 149 °F)
Factory per-setting	154 02: 58 °C (136 °F)
Temperature range for thermal disinfection	≥ 70 °C (158 °F)
Max. permissible operating temperature	90 °C (194 °F)
Control accuracy	+/- 2 K
Rated pressure	PN 16
Rated sizes	DN 15, 20, 25 (1/2, 3/4, 1)
Connection	FNPT

Dimensions								
Size DN	A1 inch (FNPT)	A2 inch (G-thread)	H1 inch	H2 inch	L1 inch	T1 inch	kvs (m ³ /h)	Cv gal/min
15	1/2	G 1/4	3.3	1.1	4.3	0.6	1.3	1.52
20	3/4	G 1/4	3.3	1.3	4.8	0.6	1.6	1.87
25	1	G 1/4	3.8	1.3	5.4	0.8	3.2	3.74



3

Installation

3.1 Assembly instructions

⚠CAUTION

The valve must be installed in an accessible place by qualified personnel. Always install valve in the direction of flow (see flow arrow on the body).

To avoid unnecessarily great resistance due to individual components, no check valves causing a high pressure loss should, if possible, be installed.

Installation of KEMPER MULTI-FIX-PLUS manual circulation regulating valves, Figure 155 6G is recommended in those sections of piping with the greatest and next greatest pressure loss in order to realise a high volume flow in such pump-remote sections.

⚠CAUTION

Multi-Therm valves must be used within hot water circulation systems that operate within the adjustable temperature range of the valve.

4

Operation

4.1 Adjustment of temperature set-point

Remove cap and unfasten the M5 grub screw with a 3/32 hex key. Turn adjustment wheel so that the required temperature is in line with the marker arrow. Tighten the grub screw and put cap back into position.

⚠CAUTION

Do not overwind the adjustment wheel over the limit stops.

The cap can be sealed.


4.2 Isolation


To isolate the pipe, turn the black cap on the pocket for a temperature probe.


4.3 Insert a temperature probe



Pull the black cap on the pocket for temperature probe and insert the optional

available temperature dial indicator Part. No. T51001550000100.









For more information, please contact:
Craig Boyce
Kemper Water Control Systems, Inc.
518 Route 513, Suite B
PO Box 195
Califon, NJ 07830 USA
Phone: +1 239 298 9273
Email: Craig.Boyce@KemperWaterControl.com



Service-Hotline +49 2761 891-800
info@kemper-olpe.de
www.kemper-olpe.de